



BRANZ Appraised

Appraisal No.474 [2005]

BRANZ Appraisals

Technical Assessments of products
for building and construction

**BRANZ
APPRAISAL
CERTIFICATE
No. 474 (2005)**

**FLEXI-SEAL®
INTERIOR
WATERPROOFING
SYSTEM**

Flexco (NZ) Ltd
P O Box 98 866
South Auckland Mail Centre
Manukau City

Tel: 09 268 6970
Fax: 09 269 6971



BRANZ Limited
Private Bag 50 908
Porirua City
New Zealand
Tel: +64 4 237 1170
Fax: +64 4 237 1171
www.branz.co.nz

BRANZ Pty Ltd
P O Box 830
Brookvale
NSW 2100
Australia
Tel: +61 2 9938 6011
Fax: +61 2 9938 6911
www.branz.com.au



Product

1.1 Flexi-Seal® Interior Waterproofing System is a two-part acrylic, liquid applied, waterproof membrane system designed for use in internal wet areas under ceramic and stone tiles.



(Shower screen not shown)

Scope

2.1 Flexi-Seal® Interior Waterproofing Membrane has been appraised for use as waterproofing membrane for internal wet areas of buildings, within the following scope:

- on floor substrates of concrete, flooring grade particleboard, plywood and fibre cement sheet tile underlay, and on wall substrates of wet area fibre cement sheet lining systems and wet area plasterboard lining systems; and,
- when protected from physical damage by ceramic tiles or stone finishes; and,
- where floors are designed and constructed such that deflections do not exceed 1/360th of the span.

2.2 The use of Flexi-Seal® Interior Waterproofing System on concrete slabs where hydrostatic or vapour pressure is present is outside the scope of this Certificate.

2.3 Movement and control joints in the substrate must be carried through to the tile finish. The design and construction of the substrate and movement and control joints is specific to each building, and therefore the responsibility of the building designer and building contractor and is outside the scope of this Certificate.

2.4 Ceramic tile or other stone finishes are outside the scope of this Certificate.

2.5 The membranes must be installed by Flexco NZ Ltd approved and trained applicators.

Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, the Flexi-Seal® Interior Waterproofing System, if designed, used, installed and maintained in accordance with the statements and conditions of this Certificate, will meet or contribute to meeting the following provisions of the NZBC:

Clause B2 DURABILITY: Performance B2.3.1 (b) 15 years. Flexi-Seal® Interior Waterproofing System meets this requirement. See Paragraph 9.1.

Clause E3 INTERNAL MOISTURE: Performance E3.3.6. Interior wet area floors and walls incorporating Flexi-Seal® Interior Waterproofing System will meet this requirement and also Functional Requirement E3.2 (b) and (c). See Paragraphs 11.1 – 11.7.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Flexi-Seal® Interior Waterproofing System meets this requirement and will not present a health hazard to people.

3.2 This Certificate appraises an Alternative Solution to meet the NZBC performance requirements.

Technical Specification

Flexi-Seal® Waterproofing System

4.1 Materials supplied by Flexco (NZ) Ltd are as follows:

Flexi-Seal®

- Flexi-Seal® is a two-part, flexible, acrylic, cementitious liquid waterproofing membrane.

Orgo'Clean®

- Orgo'Clean® is an organic cleaning concentrate for the removal of moss, mould and lichen if present on existing substrates.

Nail'n Screw Patch

- Nail'n Screw Patch is a fast setting cementitious compound used to fill nail and screw holes on plywood and particle board substrates, as well as repair chips and imperfections on concrete floors.

Primer Sealer

- Primer Sealer is a white liquid penetrative primer for concrete and wet area plasterboard substrates.

Mega Prime

- Mega Prime is a two part epoxy primer used to spot prime galvanised nails and screw heads, as well as PVC and Steel Waste traps, and to prime plywood and particle board substrates prior to the application of the Flexi-Seal®.

Reinforcing Bandage

- Reinforcing Bandage is polyester, woven bandage used in conjunction with Flexi-Seal® Primers or Flexi-Seal® 2 Part Liquid Membrane, as a bond breaking mechanism to reinforce wall/wall and wall/floor junctions in non wet and semi wet areas. For all other applications use Butylseal Tap.

Flexi-Seal® Deck Reinforcing Tape

- Flexi-Seal® Deck Reinforcing Tape is a bituminous tape to accommodate joint movement on plywood decks. The tape is a self-adhering, modified SBS rubberised asphalt tape with a white polyester upper face and is 1mm thick.

Butylseal Tape

- Butylseal Tape is a Butyl Rubber Tape used to detail/reinforce wall/wall and wall/floor joints and all internal and external exterior joints and it is available in a roll of 80 or 150 mm wide and 15 m long.

Sikasil C

- Sikasil C is a siliconised compound used as a bond breaker medium at wall/wall and wall/floor junctions.

Sikaflex 11FC

- Sikaflex 11FC is a siliconised compound designed to fill control joints such as in concrete floors.

Stencil

- A stencil is used as proof of waterproofing completion and that the system is ready to tile.

Micron Mat

- Micron Mat is a continuous filament polypropylene yarn used on decks to ensure guaranteed micron thickness.

Handling and Storage

5.1 All of the materials must be stored indoors, away from direct sunlight, heat and flame, in a dry space, at temperatures between 10°C and 32°C. Materials must not be removed from their containers until ready to use. The products have a shelf life of one year.

Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ Website for details of the current Technical Literature for Flexi-Seal® Interior Waterproofing System. The Technical Literature must be read in conjunction with this Certificate. All aspects of design, use, installation and maintenance contained within the scope of this Certificate and the Technical Literature must be followed.

Design Information

General

7.1 Flexi-Seal® Waterproofing System is for use in buildings where an impervious waterproof membrane is required to floors and walls to prevent damage to building elements and adjoining areas.

7.2 The membranes must be protected from physical damage by the application of ceramic tiles or other stone finishes.

7.3 Movement and control joints may be required depending on the shape and size of the building or room, and the tile finish specified. Design guidelines can be found in the BRANZ Tiling Good Practice Guide.

7.4 Timber framing systems must comply with NZS 3604, or where specific engineering design is used, the framing shall be of at least equivalent stiffness to the framing provisions of NZS 3604, or comply with the serviceability criteria of NZS 4203. In all cases framing must be provided so that the maximum span of the substrate as specified by the substrate manufacturer is met. Timber framing systems supporting the substrates must be constructed such that deflections do not exceed 1/360th of the span. Where NZS 3604 is used, the allowable joist spans given in Table 7.1 shall be reduced by 20%.

Substrates

Plywood

8.1 Plywood must be a minimum of 17mm thick complying with AS/NZS 2269, CD Grade Structural with sanded C face upwards and treated to H3 (CCA treated). LOSP treated plywood must not be used. The plywood must be supported with dwangs or framing with a maximum span of 400mm in each direction, fixed with 10g x 50mm stainless steel countersunk head screws at 150mm centres on the edges and 200mm through the body of the sheets.

Fibre Cement Compressed Sheet/ Fibre Cement Sheet Tile Underlay

8.2 Fibre cement compressed sheet must be manufactured to comply with the requirements of AS 2908.2 and must be specified by the manufacturer as being suitable for use as a wet area substrate. Fibre cement sheet tile underlay must be covered by a valid BRANZ Appraisal Certificate for use in internal wet areas. Installation must be in accordance with the manufacturer's instructions.

Particleboard

8.3 Particleboard must be specified for the end use in accordance with NZS 3602.

Concrete and Concrete Masonry

8.4 Concrete and concrete masonry substrates must be to a specific engineering design meeting the requirements of the NZBC, such as concrete construction to NZS 3101 and NZS 3604 Concrete Slab-On-Ground Floors and Concrete masonry to NZS 4229 and NZS 4230.

Wet Area Wall Linings

8.5 Plasterboard wall linings must be manufactured to comply with AS/NZS 2588, and be covered by a valid BRANZ Appraisal Certificate for use in internal wet areas.

8.6 Fibre Cement Sheet must be covered by a valid BRANZ Appraisal Certificate for use in wet areas.

Durability

Service Life

9.1 Flexi-Seal® Interior Waterproofing System when subjected to normal conditions of environment and use is expected to retain its integrity for a period of at least 15 years and be compatible with tiling finishes with a designed service life of 15 – 25 years.

Maintenance

10.1 No maintenance of the membranes will be required provided significant substrate movement does not occur and the tiling finish remains intact. Regular checks must be made of tiled areas to ensure they are sound and will not allow moisture to penetrate. Any cracks or damage must be repaired immediately by repairing the tiles, grout and sealants.

10.2 In the event of damage to the waterproofing membrane the tiling must be removed. Repair can then be carried out by applying a patch of suitable membrane.

10.3 Drainage outlets must be maintained to operate effectively, and tiling finishes must be kept clean.

Internal Moisture

11.1 Flexi-Seal® Interior Waterproofing System is impervious to water and when appropriately designed and installed will avoid the likelihood of water penetrating behind linings or entering concealed spaces.

11.2 Flexi-Seal® Interior Waterproofing System is suitable for use to contain accidental overflow to meet NZBC Clause E3.3.2. A means of Code Compliance for overflow is given in NZBC Acceptable Solution E3/AS1 Paragraph 2.

11.3 Surfaces must be finished with ceramic or stone tile finishes. A means of Code Compliance to NZBC Clause E3.3.3 is given in NZBC Acceptable Solution E3/AS1 Paragraph 3.1.1 (b) and 3.1.2 (b).

11.4 Falls in showers and shower areas must be a minimum of 1 in 50. In unenclosed showers, falls must extend a minimum of 1500 mm out from the shower rose. Floor wastes must be provided and the floor must fall to the outlet.

11.5 The waterproofing membrane must completely cover shower bases, and for unenclosed showers it must extend a minimum of 1500 mm out from the shower rose. Further design guidance on waterproofing wet areas, including waterproofing walls and junctions can be obtained from AS 3740, the BRANZ Tiling Good Practice Guide, and flooring and wallboard manufacturers.

11.6 Where water resistant wall finishes such as prefinished sheet materials are used, they must flash over the membrane a minimum of 30mm.

11.7 BRANZ recommends the entire floor be covered by a waterproof membrane for bath, shower and spa rooms where timber, plywood or particleboard floors are used. This is also a requirement of particleboard manufacturers.

Installation Information

Installation Skill Level Requirement

12.1 Installation of the membranes must be completed by approved applicators that have completed the Flexi-Seal® Licensed Waterproofing System training programme.

12.2 Installation of substrates must be completed by tradespersons with an understanding of internal wet area construction, in accordance with instructions given within the Flexi-Seal® Interior Waterproofing System Technical Literature and this Certificate.

Preparation of substrates

13.1 Substrates must be dry, clean and stable before installation commences. Surfaces must be even and free from nibs, sharp edges, dust, dirt or other materials such as oil, grease or concrete formwork release agents.

13.2 Concrete substrates can be checked for dryness by using a hygrometer as set out in BRANZ Bulletin No. 424. The relative humidity of the concrete must be 75% or less before membrane application.

13.3 All voids, cracks, holes, joints and excessively rough areas must be filled to achieve an even and uniform surface. Junctions of substrate abutments, such as at wall/floor and wall/wall junctions must use Flexi-Seal® Reinforcing Tape bond breaker joint system or reinforced underflashing installed as set out in the Technical Literature.

13.4 Substrates must be primed with Flexi-Seal® Primer Sealer and allowed to cure before the membrane is installed.

Membrane Installation

14.1 Installation must not be undertaken where the substrate surface temperature is below 10°C or above 35°C.

14.2 Flexi-Seal® 2 Part Liquid Membrane and Flexi-Seal® 2 Part Liquid Membrane Powder must be mixed and left to stand for 5 minutes before re-mixing, then applying.

14.3 The membrane must be applied in a minimum of two coats at the rates set out in the Technical Literature.

First coat uses the dark grey powder and subsequent coat uses the light grey powder.

14.4 Application can be made by roller (medium/long nap), brush (long bristle), or on floors with a rubber grouting blade.

14.5 Reinforcement fabric is bedded into the wet layer to provide movement protection at wall/wall and wall/floor junctions, and at any other areas such as joints in the flooring substrate, floor cracks or around penetrations in the membrane. Flexi-Seal® Reinforcing Tape must be used at junctions as set out in the Technical Literature.

14.6 Clean up may be undertaken with water.

Tiling

15.1 The membranes must be cured for at least 24 hours in summer and 48 hours in winter before tiling. The cured membranes must be protected at all times to prevent mechanical damage, so may require temporary covers until the finishing is completed.

15.2 Tiling must be undertaken in accordance with AS 3958.1 and the BRANZ Good Tiling Practice Guide. The compatibility of the tile adhesive must be confirmed with Flexco (NZ) Ltd.

Inspections

16.1 The Technical Literature must be referred to during the inspection of membrane installations by Building Consent Authorities and Territorial Authorities.

16.2 Critical areas of inspection are:

- Construction of substrates, including crack control and installation of bond breakers and movement control joints.
- Moisture content of the substrate prior to the application of the membrane.
- Acceptance of the substrate by the membrane installer prior to application of the membrane.
- Installation of the membrane to the manufacturer's instructions, particularly installation to the correct thickness and use of reinforcement.
- Membrane curing and integrity prior to the installation of tiles including protection from mechanical damage during curing and prior to tile installation.

Health and Safety

17.1 Safe use and handling procedures for the membrane are provided in the Technical Literature. The materials must be used in conjunction with the relevant Material Safety data Sheet.

Other Investigations

19.1 An assessment was made of the durability of the Flexi-Seal® Waterproofing System by BRANZ technical experts.

19.2 Site inspections were carried out by BRANZ to examine the practicability of installation.

19.3 The Technical Literature has been examined by BRANZ and found to be satisfactory.

Quality

20.1 The manufacture of the Flexi-Seal® Waterproofing Membrane has been examined by BRANZ and found to be satisfactory.

20.2 The quality of manufacture of the Flexi-Seal® Interior Waterproofing Membrane is the responsibility of RLA Polymers (NZ) Ltd.

20.3 The quality of supply to the market is the responsibility of Flexco (NZ) Ltd.

20.4 The quality of installation on site is the responsibility of the licensed applicator.



Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

18.1 Testing has been carried out by BRANZ. This testing covered durability, water absorption, thermal stability, shear, adhesion, static water head resistance, water vapour transmission and suitability over particle board. The test results were reviewed by BRANZ experts and found to be satisfactory.

Sources of Information

- ANSI 118.10:1999 Load bearing, bonded, waterproof membranes for thin-set ceramic tile and dimension stone installations.
- AS/NZS 2269 - 1994 Plywood – structural.
- AS 2358 - 1990 Adhesive for fixing ceramic tiles.
- AS 3740 - 2004 Waterproofing of wet areas within residential buildings.
- AS 3958.1 - 1991 Guide to the installation of ceramic tiles.
- ASTM C794:2001 Standard test method for adhesion-in-peel of elastomeric joint sealants.
- Good Tiling Practice, BRANZ, June 2002.
- NZS 3101:1995 Concrete structures.
- NZS 3109:1997 Concrete construction.
- NZS 3602:2003 Timber and wood-based products for use in buildings.
- NZS 3603:1994 Timber structures standard.
- NZS 3604:1999 Timber framed buildings.
- New Zealand Building Code Handbook and Approved Documents, Building Industry Authority, 1992
- The Building Regulations 1992, up to, and including October 2004 Amendment.



BRANZ

In the opinion of BRANZ, Flexi-Seal® Interior Waterproofing System is fit for purpose and will comply with the Building Code to the extent specified in this Certificate provided it is used, designed, installed and maintained as set out in this Certificate.

The Appraisal Certificate is issued only to the Certificate Holder, Flexco (NZ) Ltd, and is valid until further notice, subject to the Conditions of Certification.

Conditions of Certification

1. This Certificate:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the technical literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. The Certificate Holder:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions.
3. The product and the manufacture are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ.
4. BRANZ makes no representation as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by the Certificate Holder.
5. Any reference in this Certificate to any other publication shall be read as a reference to the version of the publication specified in this Certificate.

For BRANZ

P Robertson
Chief Executive

Date of issue: 20 June 2005