



BRANZ Appraised

Appraisal No.427 [2007]

BRANZ Appraisals

Technical Assessments of products
for building and construction

**BRANZ
APPRAISAL
CERTIFICATE
No. 427 (2007)**

**GIB AQUALINE®
WET AREA SYSTEMS**

Winstone Wallboards Limited
P O Box 12 256
Penrose
Auckland 1642

Tel: 09 633 0100
Fax: 09 633 0101
Helpline Tel: 0800 100 442
Helpline Fax: 0800 229 222
Web: www.gib.co.nz
Email: info@gib.co.nz



BRANZ Limited
Private Bag 50 908
Porirua City
New Zealand
Tel: +64 4 237 1170
Fax: +64 4 237 1171
www.branz.co.nz


BRANZ Pty Ltd
P O Box 830
Brookvale
NSW 2100
Australia
Tel: +61 2 9938 6011
Fax: +61 2 9938 6911
www.branz.com.au



Product

1.1 GIB Aqualine® Wet Area Systems are for the interior lining of timber and steel frame walls and ceilings in wet areas such as bathrooms, laundries, kitchens and toilets where a water resistant lining material is desirable.

1.2 GIB Aqualine® Wet Area Systems are based on 10 mm and 13 mm thick GIB Aqualine® water resistant plasterboard.



Scope

2.1 GIB Aqualine® Wet Area Systems have been appraised for use as a wet area wall and ceiling lining in buildings within the following scope:

- on framed walls and ceilings within the scope limitations on NZS 3604; and,
- on timber and light gauge steel framed walls and ceiling subject to specific design; and,

2.2 GIB Aqualine® may also be used to substitute for some other GIB® Plasterboards in fire-rated, sound-rated and bracing-rated wall and floor/ceiling constructions.

Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, the GIB Aqualine® Wet Area Systems, if designed, used, installed and maintained in accordance with the statements and conditions of this Certificate, will meet or contribute to meeting the following provisions of the NZBC:

Clause B1 STRUCTURE: Performance B1.3.1, B1.3.2 and B1.3.4. GIB Aqualine® Wet Area Systems meet the requirements for loads arising from self-weight, earthquake, wind and impact [i.e. B1.3.3 (a), (f), (h) and (j)]. See Paragraphs 8.1 - 8.3.

Clause B2 DURABILITY: Performance B2.3.1 (a) not less than 50 years, B2.3.1 (b) 15 years and B2.3.1 (c) 5 years. GIB Aqualine® Wet Area Systems meet these requirements. See Paragraphs 9.1 - 9.5.

Clause C3 SPREAD OF FIRE: Performance C3.3.1, C3.3.2, and C3.3.5. GIB Aqualine® Wet Area Systems meet these requirements by providing passive fire and smoke protection.

Clause E3 INTERNAL MOISTURE: Performance E3.3.4, E3.3.5 and E3.3.6. GIB Aqualine® Wet Area Systems meet these requirements. See Paragraphs 13.1 - 13.3.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. GIB Aqualine® Wet Area Systems meet this requirement and will not present a health hazard to people.

Clause G6 AIRBORNE AND IMPACT SOUND: Performance G6.3.1 and G6.3.2. GIB Aqualine® Wet Area Systems meet the requirements. See Paragraph.

3.2 This Certificate appraises an Alternative Solution in terms of New Zealand Building Code compliance.

use, installation and maintenance contained in the Technical Literature and within the scope of this Certificate must be followed.

Design Information

General

7.1 GIB Aqualine® provides a water-resistant lining as a base for finishing systems in wet areas such as bathrooms, toilets, laundries and kitchens. The typical finishes are ceramic tiles and flexible sheet vinyl to walls and paint, and wallpaper to walls and ceilings.

7.2 GIB Aqualine® must not be used in the following situations:

- For bracing applications in shower areas or adjacent baths (See Paragraphs 7.4 and 8.2).
- In areas of high humidity (above 90% RH) or continually wet such as group showers, steam rooms, or swimming pools.
- Installed over a vapour barrier.
- Applied directly to masonry, concrete or solid plaster.
- Applied over other sheet lining materials.
- Used externally of the building envelope.
- Exposed to temperatures of 52°C or greater for prolonged periods. (Refer to appliance and fitting manufacturer's for installation details.)

7.3 GIB Aqualine® may be substituted for some other GIB® Plasterboard products in specific GIB® Bracing Systems, GIB® Fire Rated Systems, GIB® Noise Control Systems and GIB Ultraline® PLUS Lining System.

Wet Areas

7.4 Wet areas are spaces where sanitary fixture and sanitary appliances are located such as bathrooms, toilets, laundries and kitchens. There are two general categories of wet areas as follows:

1. Water Splash – These are areas subject to intermittent splashing of water such as around baths, vanities, tubs and sinks.
2. Shower Areas – These are areas subject to frequent and heavy water splash such as enclosed showers, unenclosed shower zones and showers over baths.

7.5 Both the above wet area categories must be finished with surfaces and joints that are impervious and easily cleaned. Shower areas must additionally be waterproof. This can be achieved using proprietary rigid shower lining systems, flexible vinyl shower wall finish, or tiling. Tiled shower areas must include a wet area waterproofing membrane system under the tiles.

Intertency Walls – Wet Areas

7.6 Intertency drywall constructions that incorporate fire resistance and noise control must be protected from water splash. In shower areas GIB Aqualine® must not be substituted for other GIB® Plasterboards but must be an extra lining layer. Refer to the GIB Aqualine® Wet Area Systems Technical Literature.

Tiling

7.7 GIB Aqualine® is suitable as a substrate for tiling up to the following weights:

- 10 mm GIB Aqualine® up to 20kg/m²
- 13 mm GIB Aqualine® up to 32kg/m².

Note: Most ceramic and porcelain wall tiles weigh less than 20kg/m². For further information on tiling consult the BRANZ Good Practice Guide – Tiling.

Framing

7.8 Supporting framing must comprise one of the following subject to the minimum sizes, dwang centres and all other frame requirements of GIB Aqualine® Wet Area Systems Technical

Technical Specification

4.1 The GIB® plasterboards and accessories used in the GIB Aqualine® Wet Area System and supplied or specified by Winstone Wallboards Limited are as follows:

GIB Aqualine®

4.2 GIB Aqualine® is a paper-bound, modified water-resistant gypsum-plaster core sheet lining material. The sheets have a taper on the two long sheet edges. GIB Aqualine® is available in 10 mm and 13 mm sheet thicknesses, a sheet width of 1200 mm and in lengths of 2400 mm, 2700 mm, 3000 mm and 3600 mm. The maximum weights are 7.8 kg/m² and 10.2 kg/m² for 10 mm and 13 mm thick sheets respectively. GIB Aqualine® face paper is green in colour.

Fastenings

- GIB® Grabber® High Thread Drywall screws for fixing to timber:
6g x 25 mm and 32 mm.
- GIB® Grabber® Self Tapping Drywall screws for fixing to light gauge steel:
6g x 25 mm and 32 mm.
- GIB® Nails
30 mm and 40 mm x 2.8 mm

Adhesive and Sealants

- GIBFix® Wood Bond (Acrylic)
- GIBFix® All-Bond (Solvent)

GIB® Accessories and GIB® Jointing Compounds

- As specified in the GIB Aqualine® Wet Area Systems and GIB® Site Guide Technical Literature.

Finishes

4.3 Finishes such as tiling, flexible sheet vinyl, paints and wallpapers have not been assessed and are outside the scope of this Certificate.

Handling and Storage

5.1 The best results are achieved when GIB Aqualine® is treated as a finishing material and protected from damage. Sheets must be stacked flat and kept dry at all times. For limits on stack heights see the GIB® Site Guide. Sheets must be carried on edge and not dragged.

5.2 All accessories must be kept dry.

Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for the GIB Aqualine® Wet Area System. The Technical Literature must be read in conjunction with this Certificate. All aspects of design,

Literature:

- Timber framing must be designed and constructed in accordance with NZS 3604, or to a specific design using NZS 3603 and NZS 4203 (AS/NZS 1170).
- Steel framing must be designed to withstand loads in accordance with NZS 4203 (AS/NZS 1170).

Structure

Bracing

8.1 GIB Aqualine® can be used in place of GIB® Standard plasterboard in GIB® bracing elements. GIB Aqualine® can be used in place of GIB Braceline® in GIB® bracing elements 900 mm or longer, provided the perimeter of the element is fixed with GIB Braceline® Nails or GIB Braceline® screws at 100 mm centres, using the GIB Braceline® corner fixing pattern.

8.2 GIB Aqualine® must not be used for bracing in shower areas or behind baths.

Impact Resistance

8.3 GIB® plasterboards provide adequate resistance to soft body impact, based upon experience of use in domestic and light commercial applications.

Durability

Serviceable Life

9.1 GIB Aqualine® has a serviceable life of at least 15 years as a fully protected shower or water splash lining. As a general wall and ceiling lining GIB Aqualine® will have a serviceable life in excess of 50 years. The ability of GIB Aqualine® to remain durable is dependent on being protected and remaining dry in service, and being maintained in accordance with this Certificate.

Maintenance

9.2 The building must be maintained weathertight and all lining systems protected from internal and external moisture.

9.3 Finishes to water splash and shower areas, including tiles, grout, waterproof membranes, sealants and flexible sheet vinyl must be checked to ensure the integrity of the system is maintained. They must be repaired or replaced if necessary. When repairing or replacing finishes, the GIB Aqualine® substrate must be checked for defects and repaired or replaced, as required.

9.4 For flexible sheet vinyl, particular attention must be paid to joints especially at corners. Checks should be made to ensure the vinyl has not been punctured. Where damage has occurred, repairs must be made immediately.

9.5 Impact damage to GIB Aqualine® plasterboard, resulting in small holes and cracks, may be patched, stopped and finished. For larger areas of damage, expert advice on repair must be sought from Winstone Wallboards Ltd.

Outbreak of Fire

10.1 Separation or protection must be provided to GIB Aqualine® Wet Area Systems from heat sources such as stoves, heaters, flues and chimneys.

10.2 NZBC Acceptable Solution C/AS1, Part 9 and Verification Method C/VM1 provide methods for separation and protection of combustible materials from heat sources.

Spread of Fire

11.1 When 10 mm GIB Aqualine® is substituted into fire rated systems in place of 10 mm GIB Fyreline®, the FRR of that system will be maintained. Similarly, the FRR is maintained when 13 mm GIB Aqualine® is substituted for 13 mm GIB Fyreline®.

Flame Barrier

12.1 Where flame barriers are required by Acceptable Solution C/AS1 Table 6.3, GIB Aqualine® is a suitable material to provide a 10 minute flame barrier, provided all sheet joints are formed over framing, or backblocked with GIB® plasterboard.

Internal Moisture

13.1 When installed in accordance with this Certificate, GIB Aqualine® Wet Area Systems will provide wall surfaces adjacent to sanitary fixtures and sanitary appliances that are impervious and easily cleaned.

13.2 The construction methods meet with the internal moisture requirements of the NZBC Acceptable Solution E3/AS1.

13.3 To minimise internal condensation, adequate levels of ventilation and thermal resistance must be provided to all spaces where moisture may be generated.

Airborne and Impact Sound

14.1 When GIB Aqualine® is substituted into GIB® Noise Control systems in place of the equivalent thickness GIB® Standard plasterboard or GIB Fyreline®, the STC and IIC rating of that system will be maintained. When GIB Aqualine® is substituted in place of the equivalent thickness GIB Noiseline®, a small performance loss may occur.

Installation Information

Installation Skill Level Requirement

15.1 Installation of GIB Aqualine® Wet Area Systems can be carried out by any competent building contractor.

General

16.1 GIB Aqualine® Wet Area Systems must be installed in accordance with the Technical Literature. For inspection, reference must be made to the Technical Literature.

Cutting

16.2 GIB Aqualine® is easily cut by scoring the face paper with a sharp short-bladed trimming knife, and then snapping the plasterboard away from the cut face and cutting the back paper or by sawing. Use of a metal straightedge facilitates clean straight cuts. Cut edges can be tidied up by using a knife. Paper dags should be removed.

Health and Safety

16.3 Dust resulting from the sanding of stopping and finishing compounds may be a respiratory irritant, and the use of a suitable facemask is recommended.

Framing

16.4 To achieve an acceptable decorative finish, GIB Aqualine® Wet Area Systems and the GIB® Site Guide specifies that walls must not be lined unless the moisture content of timber framing is less than 18%. Winstone Wallboards Limited recommend a moisture content of 8–12% where buildings are to be air conditioned or centrally heated.

Fixing Sheets

Non-Tiled Areas

17.1 GIB Aqualine® sheets may be installed vertically or horizontally. Sheets are fixed with GIB® Grabber® screws or GIB® Nails at 300 mm centres around the perimeter of the

sheet, and with GIBFix® adhesive on all intermediate studs and dwangs. Adhesive must not be used under fasteners. A 5-10 mm gap must be left between the floor and the bottom of the sheet.

Tiled Areas

17.2 Control joints must be provided at maximum 4 m centres.

Internal corners in shower areas must be reinforced with a minimum 32 x 32 x 0.55 mm galvanised metal angle prior to lining the walls.

17.3 GIB Aqualine® sheets may be installed vertically or horizontally. Sheets are fixed with GIB® Grabber® screws at 100 mm centres to perimeter of wall and to all intermediate studs. Adhesive must not be used in place of screws.

Ceilings

17.4 Supports of timber or steel battens or ceiling joists must be 450 centres for 10 mm GIB Aqualine®, or 600 mm centres for 13 mm GIB Aqualine®.

17.5 GIB Aqualine® sheets must be fixed with GIB® Grabber® screws at 600 mm centres around perimeter and at 200 mm centre along supports. Alternatively, sheets are screw fixed at 600 mm centres along the supports and GIBFix® adhesive fixed at 200 mm centre between.

Penetrations and Sealants

18.1 All cut-outs for pipe penetrations must be made neatly using a hole saw. Cut-outs should be made approximately 12 mm diameter greater than the pipe.

18.2 A bead of silicone sealant must be placed to the full thickness of the GIB Aqualine® sheet around all pipe penetrations, at bath rims and preformed shower bases and where an impervious junction is required at the floor/wall line.

18.3 In tiled areas, a bead of silicone sealant 6 mm wide must also be placed to the full thickness of the tiles where the above situation occurs. The sealant manufacturer's technical literature must be followed for installation.

Jointing and Finishing

19.1 Jointing must be carried out in accordance with GIB® Site Guide Technical Literature.

19.2 Tiled shower areas must incorporate a waterproofing membrane over GIB Aqualine®. Waterproofing membranes are outside the scope of this Certificate and must otherwise be specified and approved.

Investigations

20.1 The GIB Aqualine® Wet Area Systems and GIB® Site Guide Technical Literature have been examined by BRANZ and found to be satisfactory.

20.2 Site visits were carried out by BRANZ to assess the practicability of the installation of the systems, and to view completed installations.

20.3 An assessment was made of the durability of the systems by BRANZ technical experts and found to be satisfactory.

20.4 Winstone Wallboards Limited GIB® plasterboards have been assessed for the following properties: MOR, MOE, paper tensile strength, paper shear strength, nail pull resistance, Hunter hardness, inspection for fungal spores, hard and soft body impact tests.

Quality

21.1 Winstone Wallboards Limited's manufacturing process and details of the quality and composition of the materials, have been examined by BRANZ and found to be satisfactory. The quality management systems of Winstone Wallboards Limited have been assessed and registered by TELARC as meeting the requirements of ISO 9001, Registration No. 581. Winstone Wallboards Limited is responsible for the quality of the product supplied.

21.2 The quality of the application and finish on site is the responsibility of the installation, stopping and finishing contractors.

21.3 Designers are responsible for the design of buildings.

21.4 Building owners are responsible for the maintenance in accordance with the instructions of Winstone Wallboards Limited.

Sources of Information

- AS/NZS 1170: 2002 Structural design actions.
- AS/NZS 2588: 1998 Gypsum Plasterboard.
- NZS 3602: 2003 Timber and wood-based products for use in building.
- NZS 3603: 1993 Timber structures standard.
- NZS 3604: 1999 Timber framed buildings.
- NZS 4203: 1992 Code of practice for general structural design and design loadings of buildings.
- BRANZ Good Practice Guide - Tiling, March 2004.
- New Zealand Building Code Handbook and Approved Documents, Building Industry Authority, 1992.
- The Building Regulations 1992, up to, and including October 2004 Amendment.



BRANZ

In the opinion of BRANZ, GIB Aqualine® Wet Area Systems are fit for purpose and will comply with the Building Code to the extent specified in this Certificate provided they are used, designed, installed and maintained as set out in this Certificate.

The Appraisal Certificate is issued only to the Certificate Holder, Winstone Wallboards Limited, and is valid until further notice, subject to the Conditions of Certification.

Conditions of Certification

1. This Certificate:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the technical literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. The Certificate Holder:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions.
3. The product and the manufacture are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ.
4. BRANZ makes no representation as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by the Certificate Holder.
5. Any reference in this Certificate to any other publication shall be read as a reference to the version of the publication specified in this Certificate.

For BRANZ

P Robertson
Chief Executive

Date of issue: 4 April 2007