VOC Content Test Certificate

Monday February 4th, 2008

Manufacturer: RLA Polymers Pty Ltd

215 Colchester Road

Kilsyth Victoria 3137

Sample Description: GS200 ADHESIVE

Date Tested: October 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification **Green Building Council of Australia** **Green Star Office Design IEQ-13**	**GS 200**
Carpet Adhesive 50 grams per Litre as VOC content material	**11 grams per Litre as VOC content per material**

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0710-21