



**BRANZ Appraised**

Appraisal No.238 [2008]

BRANZ Appraisals

Technical Assessments of products  
for building and construction

**BRANZ  
APPRAISAL  
No. 238 (2008)**

This Appraisal replaces Appraisal No.  
238 (2004) issued 27 August 2004.

**PINK® BATTS®  
GLASSWOOL  
INSULATION**

**Tasman Insulation New Zealand  
Ltd**

PO Box 12 069

Penrose

Auckland

Tel: 09 579 2139

Fax: 09 579 8806

Freeph: 0800 802 287

Web: [www.pinkbatts.co.nz](http://www.pinkbatts.co.nz)



**BRANZ**

BRANZ Limited  
Private Bag 50 908

Porirua City  
New Zealand

Tel: +64 4 237 1170

Fax: +64 4 237 1171

[www.branz.co.nz](http://www.branz.co.nz)



## Product

1.1 Pink® Batts® glasswool, is a range of resin bonded fibrous glasswool insulation used as thermal insulating material in walls, roofs, floors and ceilings of buildings.

1.2 Pink® Batts®, Building Insulation Blanket, and Cosyfloor® Glasswool Insulation products are pre-cut to suit a wide range of thermal insulation requirements and framing set-outs.

## Scope

2.1 Pink® Batts® has been appraised as a thermal insulation material for walls, ceilings, roofs, and under floors of buildings within the following scope:

- framed or part-framed domestic and commercial buildings where the insulation remains dry during its serviceable life.

2.2 Pink® Batts® must be installed in accordance with the manufacturer's Technical Literature to meet the stated thermal performance rating of the insulation. See Paragraph 6.1.



## Building Regulations

### New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, Pink® Batts®, if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet or contribute to meeting the following provisions of the NZBC:

**Clause B2 DURABILITY:** Performance B2.3.1(a) not less than 50 years and B2.3.1(b) 15 years. Pink® Batts® will meet this requirement. See Paragraph 8.1.

**Clause E3 INTERNAL MOISTURE:** Performance E3.3.1. Pink® Batts® will contribute to meeting this requirement. See Paragraphs 12.1 – 12.2.

**Clause F2 HAZARDOUS BUILDING MATERIALS:** Performance F2.3.1. Pink® Batts® meets this requirement and will not present a health hazard to people.

**Clause H1 ENERGY EFFICIENCY:** Performance H1.3.1(a) and H1.3.2 (A and B) up to the close of 29 June 2008). Pink® Batts® will contribute to meeting these requirements. See Paragraphs 13.1 – 13.10.

3.2 This is an Appraisal of an **Acceptable Solution** in terms of New Zealand Building Code Compliance. Pink® Batts® thermal resistance (R-Value) has been determined by AS/NZS 4859.1 which is an acceptable method.

# Technical Specification

## Glasswool Insulation

4.1 The Pink® Batts® glasswool product range is a resin bonded fibrous glasswool insulation. The main ingredients of Pink® Batts® glasswool are:

- Glass, recycled and/or virgin
- Cured Urea Extended Phenolic Resin
- Recycled Glass.

4.2 Cosyfloor® has Flamestop 522 (a fire retardant perforated foil insulation) bonded to one surface.

4.3 Building Insulation Blanket is supplied in rolls for commercial applications.

4.4 The product is available as set out in Table 1.

**Table 1: Product Range**

Product	R Value	Nominal Thickness (mm)	Size	Density (kg/m <sup>3</sup> )	Pieces per Bale	Coverage per Bale (m <sup>2</sup> )*	Area per Bale (m <sup>2</sup> )
Ceiling Insulation	1.8	75	1220 x 432 mm	10.5	26	14.4	13.7
Ceiling Insulation	2.2	94	1220 x 432 mm	10.0	24	13.3	12.6
Ceiling Insulation	2.6	110	1220 x 432 mm	10.2	20	11.1	10.5
Ceiling Insulation	3.2	135	1220 x 432 mm	10.2	16	8.8	8.4
Ceiling Insulation (Ultra™)	3.6	155	1220 x 432 mm	9.7	14	7.7	7.4
Ceiling Insulation	3.8	180	1220 x 432 mm	9.0	12	6.6	6.3
Ceiling Insulation (Ultra™)	4.6	175	1220 x 432 mm	13.5	10	5.5	5.3
Ceiling Insulation (Ultra™)	5.0	200	1220 x 432 mm	14.7	8	4.4	4.2
Handypack	2.2	94	610 x 432 mm	10.0	24	7.0	6.3
Wall Insulation	1.8	75	1140 x 580 mm	10.5	26	19.6	17.2
Wall Insulation	2.4	90	1140 x 580 mm	14.8	16	12.1	10.6
Wall Insulation (Ultra™)	2.6	90	1140 x 580 mm	18.5	15	11.3	9.9
Wall Insulation (Ultra™)	2.8	90	1140 x 580 mm	25.0	10	7.5	6.6
Cosyfloor 450	1.3	50	10 m x 420 mm	14.0	1	4.6	4.2
Cosyfloor 600	1.3	50	10 m x 570 mm	14.0	1	6.2	5.7
Cosyfloor	2.0	70	10 m x 420 mm	17.6	1	4.6	4.2
Building Insulation Blanket	1.8	75	8 m x 1200 mm	10.7	2	19.2	19.2
Building Insulation Blanket	1.8	75	16 m x 1200 mm	14.0	1	19.2	19.2
MasonryBlanket	1.0	40	1220 mm x 580 mm	14.0	30	22.3	21.2

\* Note: Coverage includes the total area calculated including standard timber framing set outs and is included in Table 1 as a guide only. The net area of the insulation is supplied on the packaging label. Insulation must not be fitted into sealed cavities that are less than the labeled insulation nominal thickness.

4.5 Pink® Batts® glasswool insulation is pink in colour and is packaged in pink, silver or purple print and also clear compression packaging.

Each packet is supplied with labelling in compliance with AS/NZS 4859.1.

4.6 Accessories used with Pink® Batts® which are supplied by the Insulation Installer are :

- Plastic strapping – Where plastic strapping is used to control the insulation material from movement that would affect the performance of the thermal insulation, strapping that meets the requirements of NZBC Clause B2 DURABILITY: Performance B2.3.1(a) 50 years, must be used.
- Plastic strapping fixings – Plastic strapping fixings such as hot dipped galvanised clouts or zinc plated staples that meet the requirements of NZBC Clause B2 DURABILITY: Performance B2.3.1(a) 50 years.

## Handling and Storage

5.1 Pink® Batts® must be stored under cover and in dry conditions. Heavy objects must not be stacked on the packs. The packs must be stored in an orientation that avoids excessive compression of the product.

5.2 Compression packaged glasswool is subjected to a maximum combination of compression density and storage time after which the product may not loft to its nominal thickness and therefore may not achieve its designed thermal performance.

## Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for Pink® Batts®. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

## Design Information

### General

7.1 Pink® Batts® Glasswool Insulation is designed to be used as thermal insulation to meet the energy efficiency and other NZBC insulation requirements, or to provide greater ratings when required by the designer, when installed in building walls, roofs, ceilings and floors.

7.2 Pink® Batts® (Ceiling Insulation, Wall Insulation, and Handy Packs) are designed to be friction-fitted between wall, ceiling or roof framing. They are supplied in an R-value range designed to meet a variety of construction forms that will enable compliance with the minimum requirements of NZS 4218 for roofs and walls.

7.3 Cosyfloor® is intended to fit between floor joists in new installations, or for retrofitting. The R-value of 1.3 is designed to meet the energy efficiency requirements in accordance with NZBC Acceptable Solution H1/AS1. The quoted R-value does not take into account any additional insulation performance that may accrue from the presence of a reflective air gap.

7.4 Building Insulation Blanket is designed specifically for commercial roof and commercial wall applications, where its form aids in installation by being installed in a continuous run.

7.5 Subject to the maximum compression density and storage conditions not being exceeded, all products covered by this Appraisal should recover to their nominal thickness within 24 hours after being removed from their compressed bales.

7.6 The building envelope must be constructed to meet the requirements of the NZBC. The insulation must remain dry during installation and throughout the life of the building.

7.7 To prevent moisture transfer to Pink® Batts® Glasswool Insulation, a separation (minimum 25 mm) is required between Pink® Batts® Glasswool Insulation and any flexible roof underlay. Where there is a rigid sheathing or roofing substrate such as plywood, provided there is no design requirement for roof space ventilation, a separation between Pink® Batts® Glasswool Insulation and the sheathing or substrate is not required.

7.8 The clearances specified in the Technical Literature, or specified by the manufacturer of heating appliances and recessed light fittings, must be met. The use of recessed light fittings may, therefore, reduce the thermal performance of insulated ceilings. This factor must be taken into account in the assessment of compliance with NZBC Clause H1.

7.9 When the insulation is installed in a wall with a drained cavity where the stud spacings are greater than 450 mm, an intermediate means of restraining the insulation from bulging into the cavity must be installed in accordance with NZBC Acceptable Solution E2/AS1 Paragraph 9.1.8.5.

7.10 Where the insulation is installed in exterior walls, the insulation material nominal thickness must be selected to provide a snug close fit of the insulation between building wrap and the interior wall lining.

7.11 Where the insulation material is not laid directly on a ceiling lining or over ceiling battens or joists, it must be adequately supported by galvanised wire netting or some other suitable corrosion resistant material.

7.12 Clause NZBC H1 Third Edition came into affect for Climate Zone 3 on the 31st of October 2007. It is recommended that additional requirements for Climate Zones 1 and 2 contained in Clause NZBC H1 are implemented from this date.

### Durability

#### Serviceable Life

8.1 Where the building is maintained so that provisions of the NZBC E2 and E3 Clauses are met, and where the insulation is not crushed or exposed to conditions that will diminish its

thermal performance, (e.g. moisture), then it can expect to have a serviceable life of at least 50 years. Pink® Batts® must be installed in a dry, protected construction cavity.

### Maintenance

9.1 The building must be maintained weatherproof at all times. If, during normal routine maintenance it is discovered that moisture has entered the building envelope, or that dampness has occurred because of leaking plumbing or some other source, then that source must be repaired immediately. Wet or damp insulation must be removed and then replaced with new insulation of an equivalent thermal rating. Cavities must be clean, dry and free of all contaminants and mould before fitting new insulation. NZS 4246 Paragraph 3.3 gives guidance on thermal insulation maintenance due to water damage.

### Outbreak of Fire

10.1 Pink® Batts® must be separated or protected from sources of heat such as chimneys, fireplaces, flues and fuel burning appliances in accordance with the requirements of NZBC Acceptable Solution C/AS1 Part 9.

### External Moisture

11.1 The total building envelope must comply with the requirements of NZBC E2 to ensure that the insulation remains dry in use.

11.2 The moisture content of the construction materials at the time of enclosing the insulation must meet the requirements of NZBC Acceptable Solution E2/AS1, or lower moisture content if required by the lining manufacturer.

### Internal Moisture

12.1 Buildings other than communal non-residential, commercial, industrial, outbuildings or ancillary buildings, must be constructed with an adequate combination of thermal resistance, ventilation, and space temperature must be provided to all habitable spaces, bathrooms, laundries and other spaces where moisture may be generated or may accumulate.

12.2 Roofs and walls complying with the Schedule Method for Compliance with Clause H1.3.2 (A and B) will have adequate thermal resistance. Other buildings may require more thermal insulation to satisfy the requirements of NZBC E3/AS1 than that to satisfy the energy efficiency provisions alone.

### Energy Efficiency

#### Climate Zone 3

#### Building Thermal Envelope

13.1 NZBC Verification Method H1/VM1 can be used for housing, communal residential, communal non-residential and commercial buildings.

#### Modelling of housing and smaller buildings

13.2 The modelling method described in NZS 4218 section 3.3 (as modified by NZBC Verification Method H1/VM1 Paragraphs 1.1.2 and 1.1.3) is a Verification Method for NZBC Clause H1.3.1(a) for the following types of buildings:

- a) Housing, regardless of total floor area (the method is also a means of compliance with H1.3.2 (A and B), which applies only to housing), and
- b) Small buildings other than housing having a net lettable area no greater than 300 m<sup>2</sup>.

## Building performance index for housing

13.3 Compliance with NZBC Clause H1.3.2 (A and B) (Building Performance Index or BPI) satisfies Clause H1.3.1(a).

## Modelling of large buildings other than housing

13.4 The modelling method described in NZS 4243.1 section 4.4 is a Verification Method for NZBC Clause H1.3.1(a) for buildings other than Housing having a net lettable area greater than 300 m<sup>2</sup>.

## Determining thermal resistance

13.5 The thermal resistance (R-values) of building elements may be verified by using NZS 4214.

The BRANZ 'House Insulation Guide' Third Edition provides thermal resistances of common building elements and is based on calculations using NZS 4214.

## Building Thermal Envelope

13.6 NZBC Acceptable Solution H1/AS1 can be used for housing, communal residential, communal non-residential and commercial buildings.

## Housing and Small Buildings

13.7 Construction in accordance with NZS 4218 sections 3.1 or 3.2 (as modified by NZBC Acceptable Solution H1/AS1 Paragraphs 2.1.3 and 2.1.4) satisfies NZBC H1.3.1 (a) for housing of any size and all buildings having a net lettable area no greater than 300 m<sup>2</sup>.

Construction in accordance with NZS 4218 sections 3.1 or 3.2 (as modified by NZBC Acceptable Solution H1/AS1 Paragraphs 2.1.3 and 2.1.4) satisfies NZBC H1.3.2 (A and B) for housing of any size, including the external walls of multi-unit dwellings. (Note that common walls between household units of multi-unit dwellings need not comply with NZS 4218.)

## Climate Zones 1 and 2

13.9 A building envelope meeting the requirements of one of the compliance methods of NZS 4218 will be acceptable for Housing.

13.10 For buildings other than Housing, and of less than 300 m<sup>2</sup>, a building envelope meeting the requirements of one of the compliance methods of NZS 4218 will be acceptable. For buildings larger than 300 m<sup>2</sup>, reference should be made to NZS 4243 for energy efficiency in non-residential buildings.

# Installation Information

## Installation Skill Level Requirements

14.1 Installation of Pink® Batts® must be completed by an installer with an understanding of insulation installation, in accordance with the instructions given within the Technical Literature, Installation Instructions and this Appraisal.

## General

14.1 Installation of Pink® Batts® must be in accordance with the manufacturer's Technical Literature, Installation Instructions and this Appraisal. Installation is to be carried out by trained installers only. NZS 4246 should be used as a guide for installing insulation in residential buildings.

14.2 The product must be installed only when the building is enclosed and when the construction materials have achieved the required maximum moisture content or less, to ensure the insulation does not become wet.

14.3 Pink® Batts® must be released from the packaging and allowed to re-loft prior to installation. The time to loft will depend upon the length of time the product has been packaged and stored.

14.4 Pink® Batts® are manufactured in segment and roll sizes to allow cutting to suit wall, floor and ceiling framing spaces.

(See Table 1.)

14.5 Pink® Batts® must be cut to fit into cavities where required.

14.6 Where Pink® Batts® are installed in wall cavities, the wall cavities must be completely filled to prevent sagging and thermal convection.

14.7 The insulation must either be neatly friction fitted between framing members and linings, or fitted over framing members and butted tightly so that the potential for gaps and convective heat loss is eliminated. The material must not be folded, tucked or compressed. A close, even fit provides the most efficient thermal performance.

14.8 The insulation must be continuous across the entire roof or ceiling plane between top plates of external walls, and fitted either between or over rafters, ceiling joists or truss chords. Wherever possible the insulation should be fitted beneath wiring or plumbing.

14.9 Cosyfloor® must be friction fitted between floor joists, and the foil lap stapled to the timber supports. In exposed situations, such as under pole houses, the product should be stapled through plastic strapping applied to the foil lap. Stainless steel staples should be used for maximum durability.

14.10 Where recessed light fittings are fitted, installation of the insulation material and the light fittings must be in accordance with NZBC C/AS1 Paragraph 9.4. If a gap in the insulation material is required around light fittings, the effectiveness of the thermal envelope will be diminished when the insulation does not form a continuous envelope.

## Inspections

14.11 The Technical Literature must be referred to during the inspection of Pink® Batts® installations by the building consent authorities and territorial authorities.

## Health and Safety

15.1 Pink® Batts® are easy to handle. NZS 4246 gives guidance for health and safety requirements such as personal protective clothing and installation hazard assessment.

15.2 Pink® Batts® Ultra Range of products has been assessed for its environmental impact by the New Zealand Ecolabelling Trust and complies with the requirements of the Environmental Choice Specification, Licence No. 2504017 - Thermal (resistive type) building insulants.

# Basis of Appraisal

The following is a summary of the technical investigations carried out:

## Tests

16.1 BRANZ has carried out thermal resistance testing of Pink® Batts® in accordance with AS/NZS 4859.1: 2002.

## Other Investigations

17.1 An assessment of the durability of Pink® Batts® has been made by BRANZ technical experts.

17.2 The manufacturer's Technical Literature and Installation Instructions have been reviewed by BRANZ and found to be satisfactory.

17.3 Site inspections have been undertaken by BRANZ to assess the practicability of installation.

## Quality

18.1 The manufacture of Pink® Batts® has been examined by BRANZ, including methods adopted for quality control. Details of the manufacturing processes, and quality and composition of the raw materials used were obtained and found to be satisfactory.

18.2 The quality control systems of Tasman Insulation New Zealand Ltd have been assessed and registered by Telarc SAI Limited as meeting the requirements AS/NZS ISO 9001:2000, registration No 80.

18.3 Tasman Insulation New Zealand Ltd is responsible for the quality of the product supplied.

18.4 Quality of installation of the product on site is the responsibility of the installer.

18.5 Quality of maintenance of the building to ensure the insulation material remains dry is the responsibility of the building owner.

## Sources of Information

- AS/NZS 4859.1: 2002 Materials for the thermal insulation of buildings.
- BRANZ House Insulation Guide, Third Edition 2007.
- NZS 4214: 2006 Method of determining the total thermal resistance of parts of buildings.
- NZS 4218: 2004 Energy efficiency – housing and small building envelope.
- NZS 4243: 1996 Energy efficiency – large buildings.
- NZS 4246: 2006 Energy efficiency – Installing Insulation In Residential Buildings
- Compliance Document for New Zealand Building Code External Moisture Clause E2, Department of Building and Housing, Third Edition, July 2005.
- Compliance Document for New Zealand Building Code Energy Efficiency Clause H1, Department of Building and Housing, Third Edition, August 2007.
- New Zealand Building Code Handbook, Department of Building and Housing, Third Edition, May 2007.
- The New Zealand Building Regulations 1992, up to, and including June 2007 Amendment.



**BRANZ**

**In the opinion of BRANZ, Pink® Batts® Glasswool Insulation is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.**

**The Appraisal is issued only to Tasman Insulation New Zealand Ltd, and is valid until further notice, subject to the Conditions of Appraisal.**

### Conditions of Appraisal

1. This Appraisal:
  - a) relates only to the product as described herein;
  - b) must be read, considered and used in full together with the technical literature;
  - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
  - d) is copyright of BRANZ.
2. [Tasman Insulation New Zealand Ltd](#):
  - a) continues to have the product reviewed by BRANZ;
  - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
  - c) abides by the BRANZ Appraisals Services Terms and Conditions.
3. Warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
4. BRANZ makes no representation or warranty as to:
  - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
  - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
  - c) any guarantee or warranty offered by [Tasman Insulation New Zealand Ltd](#).
5. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
6. BRANZ provides no certification, guarantee, indemnity or warranty, to [Tasman Insulation New Zealand Ltd](#) or any third party.

For BRANZ

C Preston  
Chief Executive

Date of issue: 2 April 2008